



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Noor-UI-Iman #8989, 4137 Route 1 South, Monmouth Junction, NJ 08852

**PAS Project ID :** P24-10750

**Matrix :** Drinking Water

**Report Date :** 9/30/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-10750-01	NUI-1-BF-01A	Lead	2.40	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/23/24 08:07	9/26/24 13:36
P24-10750-02	NUI-9-23-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/23/24 08:10	9/26/24 13:41

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- \* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

